

VOC Content Test Certificate

Tuesday June 2nd, 2009

Manufacturer: Winstone Wallboards Ltd (37 Felix Street, Penrose Auckland New Zealand)

Sample Description: GIB X-Block[®] joint compound for plasterboard

Date Tested: May 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p style="text-align: center;">Specification</p> <p style="text-align: center;">New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</p>	<p style="text-align: center;">GIB X-Block[®]</p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre as VOC content material</p>	<p>4 grams per Litre as VOC content material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0905-21